








**FIXINGS GUIDE**  
**SNAP RETROFIT FIRE COLLARS UP TO HP150R**



ELEMENT TYPE	RECOMMENDED FIXING	
1x13mm Fire-Rated Plasterboard Sheets or thicker	Expandable Metal Anchors Steel - Min M4 <b>07HWA4SL   07HWA4L   07HWA4XL</b>	
	Metal Threaded Rod with Metal Nuts	
	Intumescent Only Collars Exclusively: 32R, 63R, 65-80R, 110R. Do not use fixing with Spring Collars.  10g x 38mm lg Coarse Thread Steel Laminating Screw <b>09BLAM1040</b>	
Autoclaved Aerated Concrete (AAC) eg. Hebel Powerpanel	14g-10tpi x 65mm lg Steel Hex Head Screws <b>09T17B1475</b>	
Masonry Wall	6 x 35mm Steel Wedge Anchors <b>06PBZ0635</b>	
	6.5 x 40mm Steel Sleeve Anchors <b>01HS6540</b>	
Concrete Slab/Wall	5 x 30mm Steel Concrete Screw Bolts <b>03BT530</b>	
	5 x 32mm Steel Mushroom Head Spikes <b>05MH510MM</b>	
	6.5 x 40mm Steel Sleeve Anchors <b>01HS6540</b>	
	6 x 35mm Steel Wedge Anchors <b>06PBZ035</b>	

**DO NOT USE:** Either untested or not suitable for use in fire-rated applications.

Forced Entry Fixing



Nylon Nail-in Anchor



Metal Pin Anchors



Plug and Screw



Toggle Bolts



Chemical Anchors



Please note: This is a guide only. To ensure correct installation check appropriate technical data